



CE

DOP - DECLARATION OF PERFORMANCE

1. NAME AND ADDRESS OF MANUFACTURER

Replast Group Sri – Via Salt 58 33047 REMANZACCO (UD) ITALIA e ITC spa PIANDIMELETO (PU)

2. PRODUCT TYPE OF CONSTRUCTION

Corrugated tubes diam. Est. 50 double wall polyethylene high density type REFLEX-PE and ITALCOR TPC and BLACKCOR intended for the protection of underground cables ,colour red external and black inside or black external and black inside, coils 50 mt. (other possible colors outside green, yellow, blue with generic or particular marking, inside black)

3. **EUROPEAN SPECIFICATIONS APPLICABLE**

CEI EN 61386-1:2008 e CEI EN 61386-24:2010 (replace CEI EN 50086-2-4A1)
EUROPEAN DIRECTIVE B.T. 2006/95/CE, TECHNICAL ENEL DS4235 ED.IV APRIL 2007
Products meeting the safety objectives of the B.T. DIRECTIVE 2014/35 / EU annex1

4. TYPE EXPECTED TO USE THE PRODUCT

Double-wall corrugated pipes made of polyethylene high and low density type REFLEX-PE/ITALCOR TPC/BLACKCOR are designed for protection of underground cables, electric, telephone, video, computer adsl, cable question intended to be buried in the ground or in the wall, the tubes provide additional protection to cables against the effects of mechanical damage. The tubes are used in the distribution of electricity, the lighting, the distribution cable TV, telephone distribution, distribution, traffic signs and signal distribution in urban

5. PROPERTY 'MECHANICAL PHYSICAL PRODUCT

Properties / technical data	European Specification Applicable
50 mm.	CEI EN 61386-24:2010
37 mm.	CEI EN 61386-24:2010
450N/200 mm.	CEI EN 61386-24:2010
Corrugated	CEI EN 61386-24:2010
Flame propagating	CEI EN 61386-24:2010
Pliable (coil)	CEI EN 61386-24:2010
300 mm. (coil)	CEI EN 61386-24:2010
	50 mm. 37 mm. 450N/200 mm. Corrugated Flame propagating Pliable (coil)

6. INSTITUTE NAME INVOLVED IN THE ASSESSMENT AND VERIFICATION OF PERFORMANCE AND THE ISSUE OF A CERTIFICATE OF APPROVAL OF A EUROPEAN ...

IMQ S.p.A. Società a socio unico 20138 MILANO / certificate CA02.06213 e CA02.06214 e CA0205594 e EM604

The Quality Manager

Rotter B. Tiziano (Stamp and signature of respon

Remanzacco 08.04.2022 (place and date)